

### SCHEDULE 3

#### REQUIREMENTS FOR FUEL OIL STORAGE AREAS

2. The fuel oil storage area shall be surrounded by a bund capable of retaining within the area –
  - (a) in a case where all the fuel oil within the storage area is contained in one fuel storage tank, a volume of fuel oil not less than 110 per cent of the capacity of the tank;
  - (b) in a case where all the fuel oil within the storage area is contained in more than one fuel storage tank, a volume of fuel oil not less than whichever is the greater of –
    - (i) 110 per cent of the capacity of the largest tank within the storage area; and
    - (ii) 25 per cent of the total volume of such oil which could be stored in tanks within the area;
  - (c) in any other case, a volume of fuel oil not less than whichever is the greater of –
    - (i) 110 per cent of the capacity of the largest container within the storage area; and
    - (ii) 25 per cent of the total volume of such oil at any time stored within the area.