

SCHEDULE 2
PARAMETERS, MONITORING AND SAMPLING FREQUENCIES

Table B
Audit Monitoring: Type A Supplies

(1) <i>Item</i>	(2) <i>Parameters</i>	<i>Annual sampling frequency</i> <i>Volume of water distributed or produced each day</i> <i>within a supply zone (m³)(ii)(iii)</i>		
		(3) <i>≤100</i> <i>Level 1</i>	(4) <i>> 100 –</i> <i>≤1000</i> <i>Level 2</i>	(5) <i>> 1000</i> <i>Level 3(i)</i>
1.	Acrylamide	1	1	Y
2.	Aluminium	1	1	Y
3.	Antimony	1	1	Y
4.	Arsenic	1	1	Y
5.	Benzene	1	1	Y
6.	Benzo(a)pyrene	1	1	Y
7.	Boron	1	1	Y
8.	Bromate	1	1	Y
9.	Cadmium	1	1	Y
10.	Chloride	1	1	Y
11.	Chromium	1	1	Y
12.	<i>Clostridium</i> <i>perfringens</i> (including spores)	1	1	Y
13.	Copper	1	1	Y

Notes:

(i) The sampling frequency (Y) shall be determined by–

<i>Volume of water supplied each day (m³)</i>	<i>Y</i>
> 1000 – ≤ 10,000	1 + (1 for each 3,300 m ³ /d and part thereof of total volume)
> 10,000 – ≤ 100,000	3 + (1 for each 10,000 m ³ /d and part thereof of total volume)
> 100,000	10 + (1 for each 25,000 m ³ /d and part thereof of total volume)

Status: This is the original version (as it was originally made).

(1) <i>Item</i>	(2) <i>Parameters</i>	<i>Annual sampling frequency</i> <i>Volume of water distributed or produced each day</i> <i>within a supply zone (m³)(ii)(iii)</i>		
		(3) <i>≤100</i> <i>Level 1</i>	(4) <i>> 100 –</i> <i>≤1000</i> <i>Level 2</i>	(5) <i>> 1000</i> <i>Level 3(i)</i>
14.	Cyanide	1	1	Y
15.	1,2 dichloroethane	1	1	Y
16.	Enterococci	1	1	Y
17.	Epichlorohydrin	1	1	Y
18.	Fluoride	1	1	Y
19.	Iron	1	1	Y
20.	Lead	1	1	Y
21.	Manganese	1	1	Y
22.	Mercury	1	1	Y
23.	Nickel	1	1	Y
24.	Nitrate	1	1	Y
25.	Nitrite	1	1	Y
26.	Pesticides	1	1	Y
27.	Pesticides – Total	1	1	Y
28.	Polycyclic Aromatic Hydrocarbons	1	1	Y
29.	Selenium	1	1	Y
30.	Silver	1	1	Y
31.	Sodium	1	1	Y
32.	Sulphate	1	1	Y

Notes:

(i) The sampling frequency (Y) shall be determined by–

<i>Volume of water supplied each day (m³)</i>	<i>Y</i>
> 1000 – ≤ 10,000	1 + (1 for each 3,300 m ³ /d and part thereof of total volume)
> 10,000 – ≤ 100,000	3 + (1 for each 10,000 m ³ /d and part thereof of total volume)
> 100,000	10 + (1 for each 25,000 m ³ /d and part thereof of total volume)

(1) Item	(2) Parameters	Annual sampling frequency Volume of water distributed or produced each day within a supply zone (m ³)(ii)(iii)		
		(3) ≤100 Level 1	(4) > 100 – ≤1000 Level 2	(5) > 1000 Level 3(i)
33.	Tetrachloroethene and Trichloroethene	1	1	Y
34.	Tetrachloromethane	1	1	Y
35.	Total indicative dose	1	1	Y
36.	Total organic carbon	1	1	Y
37.	Trihalomethanes – Total	1	1	Y
38.	Tritium	1	1	Y
39.	Vinyl chloride	1	1	Y
40.	Zinc	1	1	Y

Notes:

(i) The sampling frequency (Y) shall be determined by–

Volume of water supplied each day (m ³)	Y
> 1000 – ≤ 10,000	1 + (1 for each 3,300 m ³ /d and part thereof of total volume)
> 10,000 – ≤ 100,000	3 + (1 for each 10,000 m ³ /d and part thereof of total volume)
> 100,000	10 + (1 for each 25,000 m ³ /d and part thereof of total volume)