

SCHEDULE 4
(See Regulation 35)

FIRE EXTINGUISHING APPARATUS

PART I

- (i) A foam-producing fire extinguisher complying in all respects with the specification issued by the British Standards Institution in respect of Portable Fire Extinguishers of the Foam Type (Chemical) and numbered B.S. 740: Part I: 1948.
- (ii) A foam-producing fire extinguisher complying in all respects with the specification issued by the British Standards Institution in respect of Portable Fire Extinguishers of the Foam Type (Gas Pressure) and number B.S. 740: Part II: 1952.
- (iii) A soda acid chemical fire extinguisher complying in all respects with the specification issued by the British Standards Institution in respect of Portable Fire Extinguishers of the Water Type (Soda Acid) and numbered B.S. 138:1948.
- (iv) A water fire extinguisher complying in all respects with the specification issued by the British Standards Institution in respect of Portable Fire Extinguishers of the Water Type (Gas Pressure) and numbered B.S. 1382:1948.
- (v) A bromochlorodifluoromethane (B.C.F.) fire extinguisher with a liquid capacity of at least 1.35 kilograms, or two such extinguishers having an aggregate such capacity, complying in all respects with the specification issued by the British Standards Institution in respect of Portable Fire Extinguishers of the Halogenated Hydrocarbon Type and numbered B.S. 1721:1968.

PART II

A fire extinguisher which complies in all respects with the specification for portable fire extinguishers issued by the British Standards Institution, published on 31st December 1976 and numbered B.S. 5423: 77 and which either—

- (a) contains water with a minimum test fire rating of 8A, or
- (b) contains foam with a minimum test fire rating of 8A and 21B, or
- (c) contains and is marked to indicate that it contains halon 1211 or halon 1301 with, in either case, a minimum test fire rating of 21B.