
STATUTORY INSTRUMENTS

1988 No. 1057

The Electricity Supply Regulations 1988

PART V

SUPPLIER'S WORKS

Precautions against excess voltage

- 22.** The supplier shall make arrangements which ensure, so far as is reasonably practicable, that—
- (a) every low voltage electric line shall be protected against danger arising from accidental contact with or leakage from any high voltage electric line; and
 - (b) where energy at a higher voltage is transformed no danger shall be caused as a result of a system at a lower voltage becoming charged above its normal voltage by leakage from or contact with the supplier's system at the higher voltage.