
STATUTORY INSTRUMENTS

1988 No. 1057

The Electricity Supply Regulations 1988

PART V

SUPPLIER'S WORKS

Precautions against supply failure

23.—(1) The supplier's works shall be so arranged, and provided where necessary with fusible cut-outs or automatic switching devices so located as to restrict, so far as is reasonably practicable, the number of consumers affected by any fault in the supplier's works.

(2) The supplier shall at all times take all reasonably practicable steps to avoid interruptions of supply resulting from his own acts.