
STATUTORY INSTRUMENTS

1989 No. 635

The Electricity at Work Regulations 1989

PART II

GENERAL

Insulation, protection and placing of conductors

7. All conductors in a system which may give rise to danger shall either—
 - (a) be suitably covered with insulating material and as necessary protected so as to prevent, so far as is reasonably practicable, danger; or
 - (b) have such precautions taken in respect of them (including, where appropriate, their being suitably placed) as will prevent, so far as is reasonably practicable, danger.