

Status: This is the original version (as it was originally made). This item of legislation is currently only available in its original format.

SCHEDULE 3

REQUIREMENTS FOR FUEL OIL STORAGE AREAS

3. The bund and the base of the storage area shall be impermeable and shall be designed and constructed so that with proper maintenance they are likely to remain so for a period of at least 20 years.