

---

STATUTORY INSTRUMENTS

---

**1992 No. 3004**

**The Workplace (Health, Safety and Welfare) Regulations 1992**

**Ventilation**

**6.**—(1) Effective and suitable provision shall be made to ensure that every enclosed workplace is ventilated by a sufficient quantity of fresh or purified air.

(2) Any plant used for the purpose of complying with paragraph (1) shall include an effective device to give visible or audible warning of any failure of the plant where necessary for reasons of health or safety.

<sup>F1</sup>(3) .....

**F1** [Reg. 6\(3\)](#) revoked (17.9.2002) by [The Health and Safety \(Miscellaneous Amendments\) Regulations 2002 \(S.I. 2002/2174\)](#), regs. 1, **6(e)**

**Commencement Information**

**II** [Reg. 6](#) in force at 1.1.1993 for specified purposes and 1.1.1996 in so far as not already in force, see [reg. 1\(2\)\(3\)](#)

**Changes to legislation:**

There are currently no known outstanding effects for the The Workplace (Health, Safety and Welfare) Regulations 1992, Section 6.