
STATUTORY INSTRUMENTS

1998 No. 1012

The Merchant Shipping (Fire Protection:
Large Ships) Regulations 1998

PART IV

FIRE PREVENTION AND FIRE APPLIANCES

TANKERS OF CLASS VII(T) OF 500 TONS OR OVER

Fixed fire-extinguishing arrangements in cargo pump rooms

32.—(1) In every category A tanker of Class VII(T) of 500 tons or over and in every Category A combination carrier of Class VII(T) of 500 tons or over, each cargo pump room shall be provided with a fixed fire-extinguishing system operated from a readily accessible position outside the pump room. The system shall use water or other medium approved by the Secretary of State.