

## SCHEDULE 1

### Authorised project

## PART 3

### Requirements

#### Detailed offshore design parameters

3.—(1) The total number of offshore substations forming part of the authorised development shall not exceed two.

(2) The dimensions of any offshore substation forming part of the authorised development (excluding masts) shall not exceed 45 metres in height when measured from LAT, 45 metres in length and 45 metres in width.

(3) Each offshore substation shall have no more than one supporting foundation.

---

#### Commencement Information

**II** Sch. 1 para. 3 in force at 6.8.2014, see [art. 1](#)

**Changes to legislation:**

There are outstanding changes not yet made by the legislation.gov.uk editorial team to The Rampion Offshore Wind Farm Order 2014. Any changes that have already been made by the team appear in the content and are referenced with annotations.

[View outstanding changes](#)

**Changes and effects yet to be applied to the whole Instrument associated Parts and Chapters:**

Whole provisions yet to be inserted into this Instrument (including any effects on those provisions):

- Sch. 1 Pt. 3 para. 15(1) substituted by [S.I. 2021/535 art. 5\(a\)](#)
- Sch. 1 Pt. 3 para. 15(2) substituted by [S.I. 2021/535 art. 5\(b\)](#)