

SCHEDULE 3

Sampling and analysis

PART 3

Monitoring for indicative dose and analytical performance characteristics

Monitoring for compliance with the ID

5.—(1) A local authority may use various reliable screening strategies to indicate the presence of radioactivity in water intended for human consumption.

(2) These strategies may include screening for—

- (a) certain radionuclides, or screening for an individual radionuclide;
- (b) gross alpha activity or gross beta activity screening.